

मुख्य अग्निशमन अधिकारी
OFFICE OF THE CHIEF FIRE OFFICER
अण्डमान तथा निकोबार द्वीप समूह
Andaman and Nicobar Islands

Clearance Number : FS/FCC/2023/786

Port Blair dated 04/02/2023

FIRE CLEARANCE CERTIFICATE

This is to certify that the **CRESCENT PUBLIC SCHOOL** situated at **WIMBERLY GUNJ ,KANYAPURAM ,FERRARGUNJ** bearing Survey No. **519/2** has been inspected and there is "**NO OBJECTION**" from fire safety point of view. The First Aid Fire Fighting arrangements in the **School** are found satisfactory and reliable for a period of one (1) year from the date of issue of this FCC, subject to no change is effected in the existing fire fighting arrangements.

Note:- Conditions for the validity of Fire Clearance Certificate(FCC)

- 1.The school consists of two separate RCC Blocks (one with G+1 floors and the other with G+2 floors) for functioning of classes IV to XII.
- 2.Building stability and satisfactory electrical installation to be ascertained from concerned agency.
- 3.FCC shall stand null and void if there is any violation in existing firefighting arrangements.
- 4.FCC may not be treated in any case for regularization of unauthorized construction, if any or violation in building plan.
- 5.All fire safety arrangements provided therein shall be maintained in good working conditions at all time and all staff members shall be well acquainted to operate all fire safety equipments.
- 6.Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 7.Trained firefighting staff should be available round the clock.
- 8.Any deviation with regard to construction etc. shall be verified by the concerned building sanctioning authority.
- 9.Means of escape shall be kept unobstructed/unlocked for unhindered evacuation in case of an emergency.
- 10.Occupant load in class room should not be more than 4 m² per students
- 11.Any flammable material for interior decoration is prohibited.

Copy to:-

- 1.The Deputy Commissioner, South Andaman District for kind information and for ensuring occupancy of the building as per approved plan.
- 2.The Panchayat Secretary, Gram Panchayat Wimberlygunj for kind information.
3. The Director of Education, P/Blair for kind information please



Inspector Fire Brigade (Port Blair)
Andaman and Nicobar Islands

To

M K MOHAMMED
WIMBERLY GUNJ
KANYAPURAM
FERRARGUNJ
SOUTH ANDAMAN - 744206